



## Addendum No. 3

**DATE: March 10, 2017**

Joliet Junior College  
1215 Houbolt Road  
Joliet, IL 60431

**TO:** Prospective Respondents  
**SUBJECT:** Addendum No. 3  
**PROJECT NAME:** Upgrade Fire Alarm System  
**JJC PROJECT NO.:** B17005

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

---

### **Additional Questions Received:**

1. Are the existing smoke and heat detector bases UL listed for use with the new replacement devices?  
***The existing bases are model SIGA-SB or SIGA-SB4 and are compatible with New specified detector models SIGA-PD or SIGA-HRS/HFS.***
2. Do the existing duct smoke detectors have to be completely replaced or can we utilize the SIGASDPCB?  
***The existing Super Duct detector models, may be replaced with a Board model SIGASDPCB or entire unit with SIGA-SD.***
3. To clarify Addendum #1, Question 18, we are currently an active EDWARDS Strategic Partner with many successful installations of the EST product since 2004. We would like to be added as an acceptable installer in the specifications section referenced. Please see the attached letter from EDWARDS confirming our active Strategic Partnership.

“In Section 16721 – Fire Alarm and Voice Communication System, Part 2 – Products, Paragraph 2.1.E, we request that our firm be added to the list of EDWARDS Strategic Partners. As seen in the list below, we are a qualified Strategic Partner with many successful EDWARDS installations. References are available upon request. At the time of bid opening, the awarded contractor/vendor must meet ALL requirements of the specs. Becoming a strategic partner, or in process of becoming a strategic partner does not qualify as a current strategic partner.”

***If the vendor/contractor is a current strategic partner with Edwards, they are qualified. However, they must be in good standing with Edwards. As part of a post-bid review, Joliet Junior College will be requesting documentation from Edwards to verify the contractor/vendor is in good standing at the time of bid opening.***

**End of Addendum #3**