



5. **Slip Sheet:** The specifications call for a slipsheet below the panels. Manufacturers do not require or recommend slipsheets below standing seam panels. Is it okay to exclude this item?  
***The specification indicates a manufacturer's recommended slip sheet, as long as one of the specified manufacturer's is used, the manufacturer's requirements/recommendations will be allowed.***
  
6. **Material:** The specifications call for steel roof panels and trims, while the plans indicate different gauges of aluminum for the gutters and downspouts. Will it be acceptable to use 24 gauge steel for all panels, trims, gutters and downspouts? This will prevent against reactions from dissimilar materials.  
***Materials are to be as specified in the documents. Dissimilar metals shall be protected as indicated in specification section 074113-3.3-D.***
  
7. Would it be okay to use 24ga kynar gutters and downspout to match the metal panel materials? It would help with avoiding dissimilar metals.  
***Materials are to be as specified in the documents. Dissimilar metals shall be protected as indicated in specification section 074113-3.3-D.***

**End of Addendum #1**