

# Addendum No. 1

### **DATE: January 8, 2018**

Joliet Junior College 1215 Houbolt Road Joliet, IL 60431

то:	Prospective Respondents
SUBJECT:	Addendum No. 1
PROJECT NAME:	Fire Extinguisher Maintenance
JJC PROJECT NO.:	B17036

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum as specified at the end of this document. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

#### **Questions Received:**

- 1. What is the total number of links with tall the systems? *See page one of the bid document*
- 2. Also, do you want hydrotesting price to include the recharge amount? *Yes*
- Do you have any additional information regarding the IT Halon system server room at the main campus. A previous report would be greatly appreciated, if not available some basic information would be very helpful. Size of tanks/Device counts/Size of room
   *9lb Halon fire extinguisher and 2- 11lb Halon fire extinguisher, Clean agent, 1-273lb/GW 478.6lb tank Name of system Kidde/Fenwal 3220 Novec fire system*
- 4. Pertaining to the JJC IT Halon System Server Room: Size of the tanks? Device counts? Size of the room? Type of agent? Brand of system? Type of panel? *See the response to question #3 above.*
- 5. When we try to visit the website provided in the bid documents, www.jjc.edu/business-auxiliary/purchasing, we are getting a "Page Not Found" error. Can you please provide the proper website so we can get the get the correct forms? <u>http://www.jjc.edu/community/vendors/current-solicitations</u>
- 6. Is there going to be a walk thru prior to the bid opening? *No*
- 7. Does the total service cost per year reflect only inspections, excluding any 6 year maintenance and hydrostatic testing required? Or does the total service cost per year need to include 6 year maintenance and hydrostatic testing as well? There is not enough

information provided if the 6 year maintenance and hydrostatic testing needs to be included in the total service on an annual basis. *6 year needs to be included* 

- 8. Will a breakdown of extinguisher sizes, types and quantities of each be available? Will the current test dates be provided for each unit we are responsible for servicing? *The breakdown is listed in the bid document.*
- Will all replacement parts, excluding damage and negligence, need to be included in the 6 year maintenance and 12 year hydrostatic as well? Yes
- 10. Regarding the (43) 5# Halatron fire extinguishers, are the extinguishers currently onsite, or do we need to include the extinguishers well?
   These extinguishers are not on site; please include pricing to buy new.
- 11. Are the (43) Halatron extinguishers replacing existing units. Are these included in the 638 count, or on year two and three will the total extinguisher count go up to 681?
  Halatron extinguishers have to be added as they are not existing. The total would go up to 681.
- 12. Are any of the extinguishers located in locked cabinets? If so, will the cabinet keys be provided?*Keys will be provided*
- 13. Fire Training Will live fire training or simulator fire training be required. Please specify. Also, will there be a total of 150 attendees of the fire training, or 150 per class? Live fire training will be required. See training in bid document. Total of 150 approximately 12 students per class.
- 14. Will the number of fusible links and rubber nozzle caps on each kitchen system be provided? No
- 15. Will the previous inspection reports available? *No*
- 16. Will the hydrostatic test dates of kitchen system cylinders be provided so we know when a cylinder will be due for hydrostatic test? *Yes*
- 17. Will the number of devices and cylinders with sizes for halon system be provided? Are there any drawings of the system available?*Yes, but drawings are not available.*
- 18. What is the total number of links with tall the systems? *This information is listed within the bid document.*
- 19. Also, do you want hydrotesting price to include the recharge amount? *Yes*

### End of Addendum #1

## Addendum No. 1



### **DATE: January 8, 2018**

Joliet Junior College 1215 Houbolt Road Joliet, IL 60431

TO:Prospective RespondentsSUBJECT:Addendum No. 1PROJECT NAME:Fire Extinguisher MaintenanceJJC PROJECT NO.:B17036

Please acknowledge receipt of these addenda by including this page with your proposal. Include your company name, printed name, title, and signature in your acknowledgement below. Failure to do so could result in disqualification of your bid.

Issued by:

Janice Reedus Director of Business & Auxiliary Services Joliet Junior College 815.280.6643

I acknowledge receipt of Addendum #1.

Company Name

Printed Name

Title

Signature