



**Addendum No. 3**  
Page 1 of 1

**DATE: March 6, 2018**

Joliet Junior College  
1215 Houbolt Road  
Joliet, IL 60431

**TO:** Prospective Bidders  
**SUBJECT:** Addendum No. 3  
**PROJECT NAME:** Steam Pipe System Replacement with Condensing Boilers  
**JJC PROJECT NO.:** B18001

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

---

**Additional Question:**

1. The drawings show where we are to tie into the existing system piping. Are there isolation valves that keep the equipment rooms isolated from the rest of the building so we would not have to drain the entire building and then have to refill, vent, and re-chemical the whole building and not just the equipment rooms.

***We are not aware of any isolation valves between the boiler house and main building.***

**End of Addendum #3**