



Addendum No. 1
Page 1 of 1

DATE: April 21, 2023

Joliet Junior College
1215 Houbolt Road
Joliet, IL 60431

TO: Prospective Bidders
SUBJECT: Addendum No. 1
PROJECT NAME: Exterior Wall Façade Repairs (Rebid)
JJC PROJECT NO.: B23019R

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

Questions Received:

1. Can areas that call for new finish on all walls corner to corner use integral color in finish? Or is painting required?

Answer: Integral color may be used as long as it matches adjacent finish color. Otherwise, painting will be required.

2. I'm seeing exterior façade repairs to EIFS and stucco. Is there demolition on this project?

Answer: The required demolition is whatever is necessary for proper surface prep for new finishes.

End of Addendum #1