



**Addendum No. 1**  
Page 1 of 1

**DATE: November 9, 2023**

Joliet Junior College  
1215 Houbolt Road  
Joliet, IL 60431

**TO:** Prospective Bidders  
**SUBJECT:** Addendum No. 1  
**PROJECT NAME:** Buildings C, E, & G Mechanical ACM Removal  
**JJC PROJECT NO.:** B24009

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

---

**Question Received:**

1. Will the JJC staff/plumber identify and make the garden hose connection to the nearest water source for the Mechanical Room work areas, as required?  
***JJC will identify hose connection points, but contractors are responsible to provide hose and hose hook them up.***

**Additional Notes:**

1. The Background checks shall NOT be required as stipulated in Section 01010 – Proposal Form, Number 1. Scope of Work, paragraph B of TEM Environmental’s Request for Proposals dated October 17, 2023
2. Where HEPA negative air exhaust will be vented out of the building through doors, the abatement contractor should secure the opening with a plywood blank and manifold for exhaust tubes such that it prevents entry
3. JJC will make electrical connections for the abatement contractor where necessary; abatement contractor to supply whip
4. Schedule may be as follows: (Awarded contractor to coordinate with owner representative.)
  - a. Monday December 18<sup>th</sup> to Wednesday 20<sup>th</sup> after 5 pm to 5 am
  - b. Thursday December 21<sup>st</sup> to January 1<sup>st</sup> anytime during the day, afternoon or night shift
  - c. Tuesday January 2<sup>nd</sup> through January 5<sup>th</sup> after 5 pm to 5 am

**End of Addendum #1**