



Addendum No. 2
Page 1 of 2

DATE: February 13, 2024

Joliet Junior College
1215 Houbolt Road
Joliet, IL 60431

TO: Prospective Bidders
SUBJECT: Addendum No. 2
PROJECT NAME: Building A Testing Center HVAC Renovation
JJC PROJECT NO.: B24011

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

Questions Received:

1. Will you bid the post-construction cleaning directly with me or should I wait to be contacted by a prime contractor?

Response: We do not bid out post construction cleaning. Contractors are responsible to clean site.

2. I just spoke with Trane and the only way to quote parts for this unit is to provide them with the serial # of the HP unit. Please request this information from the engineer.

Response: The serial number is W10G13890



3. The term "drive package" is not correct. Do they mean motor? If so, we need HP serial #.

Response: Drive package would be motor and sheaves as required to meet the new performance requirements. With the model #, serial # and performance schedule on the drawings there should be enough information.

End of Addendum #2