



**Addendum No. 3**  
Page 1 of 1

**DATE: August 5, 2024**

Joliet Junior College  
1215 Houbolt Road  
Joliet, IL 60431

**TO:** Prospective Bidders  
**SUBJECT:** Addendum No. 3  
**PROJECT NAME:** **Mental Health & Awareness Center**  
**JJC PROJECT NO.:** B25001

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

---

**ADDITIONAL QUESTIONS RECEIVED**

1. Door #J0003A states it is to be an aluminum door per the door schedule on sheet A5.0. The demo plan sheet D1 states the existing door/framing is hollow metal. Please if this new door is hollow metal or aluminum.  
***New Door to be aluminum in existing hollow metal window system frame.***
2. Depending on how #1 above is answered, the existing door frame may also need to be replaced in order to adhere to the new door hardware asked for on set 1.01. It is not known if the existing system can accommodate the new electrified hardware asked for and thus may need to be replaced. Can pictures be provided of what is existing here.  
***Existing frame to remain part of exterior hollow metal window system. Visit site during the walk-through schedule for Tuesday, August 6 at 9:00am to verify what is existing. See addendum #1 for upcoming walk-through information.***
3. Please advise how tall detail 9/A5.0 should be figured since interior views/section cut was not provided. 8'-0" ceiling is stated on sheet A4.0, but we do not know if the existing framing is full height.  
***Interior wall partition is indicated for type on Floor plan legend.***
4. Please advise what finish is needed for detail 9/A5.0 for the partition to match the existing framing.  
***Only material to match existing window frame is acoustic closure foam specified on drawing detail.***

**End of Addendum #3**