



**Addendum No. 2**  
**Page 1 of 1**

**DATE: October 10, 2024**

Joliet Junior College  
1215 Houbolt Road  
Joliet, IL 60431

**TO:** Prospective Bidders  
**SUBJECT:** Addendum No. 2  
**PROJECT NAME:** **Replace DHW Tank & Underground Irrigation Piping**  
**JJC PROJECT NO.:** B25006

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

---

**QUESTIONS RECEIVED:**

1. On the drawings, the irrigation piping is listed as polyurethane pipe but the specifications call for high density polyethylene piping (HDPE). Please verify which is the correct material. **Use high density polyethylene piping (HDPE)**
2. If we have to remove a tree, does it have to be replaced? **No, path should not require removal or replacing trees**
3. Are there specific trees identified for needing protection? **No**
4. What is the bury depth of the existing irrigation system? **Existing piping is approximately 3'-4' deep.**
5. What is the bury depth of the new irrigation piping? **4'**
6. Are there any private utilities on this site that would require a private utilities location contractor, separate from a standard JULIE locate? **JJC will provide utility locates.**
7. Have the soils been tested for environmental contamination? **No, if soil testing is required it will be charged to the allowance.**
8. Can spoils be considered non-contaminated for hauling and disposal purposes? **Yes**
9. Would it be possible for me to see the site? **Yes, you can view the exterior conditions any time. If you need to see interior conditions please contact Dave Kozlowski at 815-280-2577.**

**End of Addendum #2**