



**Addendum No. 1**  
Page 1 of 1

**DATE:** January 23, 2025

Joliet Junior College  
1215 Houbolt Road  
Joliet, IL 60431

**TO:** Prospective Bidders  
**SUBJECT:** Addendum No. 1  
**PROJECT NAME:** **Weitendorf Animal Wing AHU Replacement**  
**JJC PROJECT NO.:** B25013

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

---

**QUESTIONS RECEIVED:**

1. Is this project Tax Exempt?  
**Answer: Yes.**
2. Will a city permit be required?  
**Answer: No.**
3. What is the purpose of the Cupola being removed and reinstalled with new louvers? It appears to be in good shape and the ductwork should be able to be disconnect from the interior. A sheet metal cap can be used if you want to close it off to the exterior.  
**Answer: Install new louvers after completely removing the existing exhaust ductwork. It is acceptable to install new louvers without removing the entire cupola. New louvers should also have a screen installed to keep insects out of the building.**
4. What type of fire alarm are we tying smoke detector into? Do you have a special company you use?  
**Answer: A new Edwards fire alarm panel was recently installed on-site. Convergent is our fire alarm company.**  
**Contact Trey Cowan**  
**Cell: 815-641-7752**  
**Office: 847-585-8867**  
**Alt. Office 847-620-5000**  
**Email: trey.cowan@convergint.com**

**End of Addendum #1**