



Addendum No. 1
Page 1 of 2

DATE: February 19, 2026

Joliet Junior College
1215 Houbolt Road
Joliet, IL 60431

TO: Prospective Bidders
SUBJECT: Addendum No. 1
PROJECT NAME: Vet Tech Lab Cabinet Install
JJC PROJECT NO.: B26019

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

Questions Received:

Alt 1: Please clarify the glazing material for the aluminum doors. Aluminum framed storefront specification 084313 page 4, sec 2.03 para. B glazing states to see section 88010 Acrylic glazing. I assume this is for the aluminum doors. Spec 88010 is not found in the spec book. Thank you.

Answer: The specifications are on the drawings A2 and A3, there is not a separate specification document. The aluminum framed entrance and storefronts states to comply with Section 088000 Glazing, which calls out for Safety Glazing "G-1" that is noted on sheet A1.

End of Addendum #1